

**ADDENDUM NO. 1**  
**September 16, 2024**

**PROJECT: CITY OF AZLE**  
**WALNUT CREEK FORCE MAIN**

**BID DATE: SEPTEMBER 19, 2024**

The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

**1) Information for Bidders: Instructions on how to address bids shall be changed to:**

“Each bid must be submitted in a sealed envelope addressed to the Purchasing Agent. Each sealed envelope containing a bid must be plainly marked on the outside as **“WALNUT CREEK FORCE MAIN - (Azle bid number 2024-010)”** and the envelope shall bear on the outside the Bidder's name and address. If forwarded by mail, the sealed envelope containing the bid must be enclosed in another envelope and addressed to the Purchasing Agent, City of Azle, 505 W. Main Street, Azle, Texas, 76020.”

- 2) The encasement for the bore and encasement shown on Sheet 09 shall be 14”.**
- 3) The units for Bid Item No. 2 should be LF.**
- 4) HDPE pipe may be either IPS or DIPS as stated in the specifications.**
- 5) A stormwater permit will not be required for this project. A plan for erosion control shall be provided to the City’s stormwater manager to insure proper controls.**
- 6) The existing combination air valve at Sta 0+00 will remain. Only two combination air valves are to be replaced.**
- 7) Mueller Hymax Ductile Iron Fittings may be used with SDR 26 PVC. Alternatively, DR 25 PVC pipe will be accepted in lieu of SDR 26.**

**Prepared by:**

\_\_\_\_\_  
**Bidder’s Acknowledgment**

**JACOB | MARTIN**  
**TBPE Firm No. 2448**

\_\_\_\_\_  
**Date**