

**ADDENDUM NO. 2
JANUARY 17, 2025**

**PROJECT: CITY OF AZLE
WALNUT CREEK LIFT STATION**

BID DATE: January 23, 2025

The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

- 1) **The time for completion of this project will be changed to 310 days. The order for the lift station equipment will take place in advance of the award of this contract. If lift station equipment delivery delays completion, additional time will be allotted for the general contract.**
- 2) **The existing pumps and floats shall be removed and turned over to the City per Sheet C-04. All piping that is not reused shall be removed and disposed of.**
- 3) **The Contractor shall relocate the existing bypass pump suction line as described in the plans and coordinate with the City for the operation of the bypass pump. The existing, east side submersible pump will remain in service as long as possible to limit the time the bypass pump will be required. This shall be until final electrical and pump header tie-ins must be made. Contractor shall coordinate disconnection of existing equipment and switchovers accordingly.**

Prepared by:

**JACOB | MARTIN
TBPE Firm No. 2448**

Bidder's Acknowledgment

Date