

ADDENDUM NO. 3
December 3, 2024

PROJECT: FORT GRIFFIN SUD
HUBBARD CREEK RESERVOIR CROSSING

BID DATE: DECEMBER 10, 2024 AT 1:30 PM

The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

- 1) The bids for this project will be opened and read aloud at the Albany Volunteer Fire Department at 609 Railroad Street, Albany, Texas 76430 at 2:00 PM on December 10, 2024. **The bids shall still be delivered to the SUD office as stated in the advertisement for bids and the time for bids to be received will still be December 10, at 1:30 PM.**
- 2) Fusible American AVK Resilient Seated Gate Valves, or equal, will be acceptable on this project.
- 3) Anchoring of wire line within the 20' easement for the water line in the lake will be allowed.
- 4) Water used during construction may be taken from the lake.
- 5) An additional 150' x 150' temporary easement area will be available on the west side of the lake for staging.
- 6) The minimum depth of the bore below the lake bottom shall be 10'.

Prepared by:

JACOB | MARTIN
TBPE Firm No. 2448

Bidder's Acknowledgment

Date