

**ADDENDUM NO. 3
JANUARY 10, 2025**

**PROJECT: CITY OF RISING STAR
TWDB WATER LINE REPLACEMENT**

BID DATE: JANUARY 15, 2025

The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

1) PLAN SHEETS

- a) Sheet 10 – Trench Outside of Street
 - i) Per the plan sheet detail, pipe bedding from 4 inches below the pipe to 4 inches above the pipe is shown to be imported buckshot gravel or approved equal. Contractor may use excavated fines material provided that this material contains no rocks greater than 4 inches in diameter, and is suitable for compaction and use as bedding for proposed pipe. If excavated material is not suitable, contractor shall be responsible for importing bedding material per the existing plan detail at no extra cost.
 - ii) This change is for trenches outside of roadway areas only. The other two details on sheet 10 shall still apply for trench repair in roadway areas.

Bidder's Acknowledgment

Date

Prepared by:

**JACOB | MARTIN
TBPE Firm No. 2448**



01/10/2025