

ADDENDUM NO. 1
July 16, 2025

PROJECT: COKE COUNTY WSC
AIR RELEASE VALVE REPLACEMENT MATERIALS PURCHASE

BID DATE: July 24, 2025 at 5:00 PM

The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

1) SPECIFICATIONS

a) Specification 33-06-01

- i) Section 2.4 – Corporation Stops – Inlet connection shall be suitable for threaded connection to tapping sleeve. Outlet connection shall be suitable for connection to DR9 HDPE piping as shown on the plan sheet detail.

Bidder's Acknowledgment

Date

Prepared by:

JACOB | MARTIN
TBPE Firm No. 2448



07/16/2025