

**ADDENDUM NO. 2**  
**July 17, 2025**

**PROJECT: COKE COUNTY WSC**  
**AIR RELEASE VALVE REPLACEMENT MATERIALS PURCHASE**

**BID DATE: July 24, 2025 at 5:00 PM**

The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

**1) SPECIFICATIONS**

**a) Specification 33-02-08**

- i) Section 2.2A – Combination Air Valve – valves shall be rated for pressures up to 150 psi.

\_\_\_\_\_  
**Bidder's Acknowledgment**

\_\_\_\_\_  
**Date**

**Prepared by:**

**JACOB | MARTIN**  
**TBPE Firm No. 2448**



**07/17/2025**