

ADDENDUM NO. 1

April 28, 2022

**PROJECT: PARKER WATER SUPPLY CORPORATION
C.R. 1107A WATER LINE UPGRADES**

BID DATE: May 03, 2022

The following changes and/or additions shall be made to the Plans, Specifications and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

1. The attached revised bid schedule shall be used.
2. Slick bores for driveways shall be considered incidental to the water line.
3. References to the use of 160 psi pressure rated pipe is revised to 200 psi as indicated on the plan sheets. Any mention of 160 psi pipe shall be disregarded.

Prepared by:

JACOB | MARTIN
1508 Santa Fe Drive, Suite 203
Weatherford, Texas 76086
TBPE Firm No. 2448

Bidder's Acknowledgment

Date

**PARKER W.S.C.
C.R. 1107A WATER LINE UPGRADES
REVISED BASE BID SCHEDULE A**

Show prices in numerals. Round off unit prices to two decimal places only.

These Bid Prices must include all labor, materials, equipment, insurance, overhead, superintendence, transportation, taxes, permits, profits & incidentals to cover the finished Work called for in the Contract Documents.

For all Labor, Materials, Equipment and Incidentals to Furnish and Install the Following:

Bid Item	Description	Est. Qty.	Unit	Unit Price	Extended Amount
1	Water Pipe - 200 PSI Pressure Rating	7,940	LF	\$	\$
2	14" Bore & Encasement	125	LF	\$	\$
3	8" x 4" TS & TV	1	EA	\$	\$
4	1" Air Valve	2	EA	\$	\$
5	Flush Valve	2	EA	\$	\$
6	8" Gate Valve	1	EA	\$	\$
7	3" Gate Valve	3	EA	\$	\$
8	Existing Water Main Connectin	3	EA	\$	\$
9	Water Meter Reconnect	3	EA	\$	\$
10	Metal Tape	7,940	LF	\$	\$
11	ROW Markers	8	EA	\$	\$
TOTAL BASE BID A (Items 1 -11)					\$