

**ADDENDUM NO. 1**  
**4/28/2022**

**PROJECT: CITY OF GOREE**  
**ELEVATED STORAGE TANK INTERIOR REHABILITATION**

**BID DATE: May 5, 2022**

The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

**1) GENERAL**

Bid Item 2: The sandblast and recoat of the interior shall include the wet riser pipe. The diameter of the riser pipe is 36”.

\_\_\_\_\_  
**Bidder's Acknowledgment**

\_\_\_\_\_  
**Date**

**Prepared by:**

**JACOB | MARTIN**  
**TBPE Firm No. 2448**

