

ADDENDUM NO. 1
June 23, 2022

**PROJECT: Hamlin Independent School District
Parking Lot Pavement Improvements**

BID DATE: June 27, 2022, 2:00 PM

The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

1) GENERAL


Replace original bid schedule with the revised bid schedule attached. Alternate bid items have been added to provide a full depth pavement repair option to the project. Should availability of cement be an issue, prospective bidders may bid the project excluding base bid item #5 and include alternate bid items 5A, 5B, and 5C.

Bidder's Acknowledgment

Date

Prepared by:

JACOB | MARTIN
TBPE Firm No. 2448



**HAMLIN ISD
PAVEMENT REHABILITATION
BASE BID SCHEDULE A**

Show prices in numerals. Round off unit prices to two decimal places only.

These Bid Prices must include all labor, materials, equipment, insurance, overhead, superintendence, transportation, taxes, permits, profits & incidentals to cover the finished Work called for in the Contract Documents.

For all Labor, Materials, Equipment and Incidentals to Furnish and Install the Following:

Bid Item	Description	Est. Qty.	Unit	Unit Price	Extended Amount
1	Mobilization, Bonds, and Insurance	1	LS	\$	\$
2	7" Thick Reinforced Concrete Driveway	125	SY	\$	\$
3	AEP Prime Coat	3233	GAL	\$	\$
4	2" Type "D" Hot Mix Asphaltic Surfacing (220#SY)	10816	SY	\$	\$
5	Pulverize 6" Existing Material, Cement Stabilize 6" Existing Material	8701	SY	\$	\$
6	Mill Existing Asphalt Pavement	2115	SY	\$	\$
7	Pavement Marking 4" White, Non-Reflective	1	LS	\$	\$
8	Wheel Stops	8	EA	\$	\$
TOTAL BASE BID A (Items 1 -8)					\$

NOTE: Total Alternate Bid A would be a replacement of Base Bid Item #5.

Bid Item	Description	Est. Qty.	Unit	Unit Price	Extended Amount
5A	6" Subgrade Preparation	8701	SY	\$	\$
5B	10" Crushed Limestone Base Course	2417	CY	\$	\$
5C	Remove and Dispose of Existing Base and Asphalt (10")	2417	CY	\$	\$
TOTAL ALTERNATE BID A (Items 1 -3)					\$

*6" subgrade preparation shall include scarification and recompaction of existing material to 95% of ASTM D1557 max dry density at or above optimum moisture content. Crushed Limestone Base Course shall be Type A Grade 2 or better and compacted to a minimum of 95% density per ASTM D-698 within 3% of optimum moisture content.