

ADDENDUM NO. 1

July 21, 2022

**PROJECT: CITY OF KEENE
LEWIS LANE & HILLCREST STREET SEWER LINE REPLACEMENT**

BID DATE: August 9, 2022

The following changes and/or additions shall be made to the Plans, Specifications and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

1. The pipe to be used for the new sewer line will be DR 17 HDPE. References in the plans and bid schedule to DR 9 or DR 19 pipe shall be replaced with DR 17.
2. Item 5, Service Reconnect of the bid schedule shall include reconnecting to the existing lateral to the main line only.
3. Backfill for bore pits may be existing, excavated material. Topsoil shall be held back and replaced after backfill operations.

Prepared by:

JACOB | MARTIN
1508 Santa Fe Drive, Suite 203
Weatherford, Texas 76086
TBPE Firm No. 2448

Bidder's Acknowledgment

Date