

**ADDENDUM NO. 3**

**December 2, 2022**

**PROJECT: FORT GRIFFIN SUD  
HUBBARD CREEK RESERVOIR CROSSING**

**BID DATE: December 5, 2022**

The following changes and/or additions shall be made to the Plans, Specifications and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

1. Following is offered to clarify previous addenda regarding the pipe size and material. The base bid for this project shall include 8” DR 9 HDPE water line. The Contractor may propose larger pipe or pipe of different material, but sufficient documentation must be provided showing that such alternate material and size is adequate for this application.

**Prepared by:**

**JACOB | MARTIN**  
**1508 Santa Fe Drive, Suite 203**  
**Weatherford, Texas 76086**  
**TBPE Firm No. 2448**

\_\_\_\_\_  
**Bidder's Acknowledgment**

\_\_\_\_\_  
**Date**