

ADDENDUM NO. 1
April 30, 2024

**PROJECT: CITY OF COLORADO CITY
HOSPITAL WATER SUPPLY**

BID DATE: May 7, 2024

The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

1) PLAN SHEETS

- a) Sheet 8 & 9 – pressure relief valves for meter / fire line reconnects shall be Cla-Val 90-01 or approved equal. A 1” valve shall be utilized on 5/8 x 3/4” meter reconnections with reducers added as necessary. The 2” valves may be threaded or flanged. Calculated inlet pressure is 95-100 psi. Outlet pressure shall be adjustable, but will initially be in the 55-60 psi range.

Prepared by:

JACOB | MARTIN
TBPE Firm No. 2448

Bidder's Acknowledgment

Date

