



ADDENDUM NO. 2 October 2, 2025

PROJECT: CITY OF ABILENE

SECOND PRESSURE PLANE - 1.5 MG ELEVATED STORAGE TANK

BID DATE: October 8, 2025

The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

CONTRACT DOCUMENTS

1. General Conditions Item 31 and Supplementary Conditions Item 10: Clarification - Weekend work will be allowed on a case-by-case basis and only after approval by Owner and Engineer.

SPECIFICATIONS

1. Section 33 02 02: Item 1.4.B shall be **removed** from this specification section.

PLANS

- 1. Plan Sheet 02: Under the Mixing Notes Certisafe mixers by Kasco shall be <u>added</u> as an equivalent and approved alternative mixing system for the tank.
- 2. Plan Sheet 03: The depth of the 30" water line that is to be connected to is approximately 4 feet deep.
- 3. Plan Sheet 03: The length of 30" water line that will need to be isolated and drained for the 30" water line connection is approximately 4,200 linear feet.
- 4. Plan Sheet 14: Contractor is to provide and install both the conduit <u>and</u> wiring from the mixer control panel to the tank mixer per NEC code. Contractor is responsible for providing and installing all electrical components per the mixer manufacturer's requirements for a complete and operational system.

Bidder's Acknowledgment	
Data	

Prepared by:

HENRY K. HARLE

98381

CENSE

10-2-25