

ADDENDUM NO. 2
September 10, 2024

PROJECT: CITY OF AZLE
ELEVATED TANK REHABILITATION

BID DATE: September 12, 2024

The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

- 1) **No guard rails or platforms are required on any of the ladders. The intent is for standoffs (brackets supporting the ladder and projecting it away from the structure 10”) to be installed at 10’ intervals. Welds shall be cleaned and coated per the specs. Bid Item 7 will still apply.**
- 2) **Specification Item 13 07 02, Section 3.2, Items 2 and 4 shall be disregarded. It is not intended to replace any anchor bolts.**
- 3) **The existing coatings do not contain lead.**

Bidder’s Acknowledgment

Date

Prepared by:

JACOB | MARTIN
TBPE Firm No. 2448