

**ADDENDUM NO. 01
FEBRUARY 12, 2025**

**PROJECT: CITY OF WEST TAWAKONI
2023 CDBG WTP IMPROVEMENTS - CID 03 - PUMPS AND FILTER INSTALL**

BID DATE: FEBRUARY 18, 2025

The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

- 1) Please note that the 1,050 gpm vertical turbine pumps are not can pumps.
- 2) The online turbidity meter listed under Spec 25 02 01-1 as Hach TU5300 SC is further clarified by part number LXV 445.99.10112.

Bidder's Acknowledgment

Date

Prepared by:

**JACOB | MARTIN
TBPE Firm No. 2448**