

ADDENDUM NO. 2
6/3/2024

**PROJECT: TOWN OF BUFFALO GAP
EMERGENCY GENERATORS**

BID DATE: JUNE 11, 2024 (Changed with this addendum)

The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

1) GENERAL

- a. The bid date has been changed to June 11, 2024 at 3:00 PM.

2) PLAN SHEETS

- a. The wattage calculations in the Hargesheimer Pump Station panel "MDP" schedule on sheet 14 for the 75 HP pumps are incorrect. This wattage should be approximately 80 kW per pump instead of the 46,080 watts shown in the panel schedule.

3) SPECIFICATIONS

- a. SECTION 33 04 01: The Barnes 4XSCMC 10 HP pump is an acceptable alternative to the Flygt Pump specified for the Esta Neva lift station.

Prepared by:

JACOB | MARTIN
TBPE Firm No. 2448

Bidder's Acknowledgment

Date

