




ADDENDUM NO. 2
June 6th, 2024

**PROJECT: ANSON INDEPENDENT SCHOOL DISTRICT
VOC. TECH RENOVATION**

BID DATE: June 11th, 2024 AT 2:00 PM



The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum on the Construction Costs Form.

GENERAL

Addendum 1 was issued with a typo on question 6; no answer was given, just the question restated. See below for clarification.

QUESTIONS

Item #Q6 Question: Is GFCI protection required for all 120-volt 20-amp circuits in Shop 111, Bus shop 116 and Bus Maintenance 118?

Answer: All receptacles, per 2023 NEC 210.8(B)(10) will need to have ground fault protection of personnel.

END OF ADDENDUM