



ADDENDUM NO. 4
8/1/2025

PROJECT: CITY OF ABILENE
I-20 UTILITY RELOCATES - WORK AUTHORIZATION NO.1

BID DATE: AUGUST 7, 2025

The following changes and/or additions shall be made to the Plans, Specifications, and Contract Documents for the above referenced project. Bidder shall acknowledge receipt of this Addendum by signing below and returning this Addendum with the Bid.

1) PLANS

- a) Ductile Iron Pipe (DIP) may be used in lieu of PVC for water lines 30" diameter and larger (Conflicts 1008, 1012 & 1013), at bidder's option. Bidder shall clearly state with their bid if using DIP in lieu of PVC. If using DIP, ensure the pressure rating of the pipe and gaskets meets or exceeds that of the PVC pipe specified on the Plans.
- b) Conflict 1008 (Sheet 18): If using DIP, the portion of pipe from the butterfly valve to the cap (Sta. 1+34-1+59) shall remain PVC as specified for future connection.

Bidder's Acknowledgment

Date

Prepared by:

JACOB | MARTIN
TBPE Firm No. 2448

